



Send To: 00010

Mr. Joe Sokolowski
3 Springs Water Company
1800 Pine Run Road
Laurel Run, PA 18702

Facility: 00011

3 Springs Water Company
1800 Pine Run Road
Laurel Run PA 18702
United States

Result	COMPLETE	Report Date	26-APR-2018
Customer Name	3 Springs Water Company		
Tested To	USFDA CFR Title 21 Part 165.110		
Description	Spring Source Water		
Test Type	Source Water		
Job Number	A-00287001		
Project Number	10067932 (CLAB)		
Project Manager	Anna Baker		

Thank you for having your product tested by NSF International.

Please contact your Project Manager if you have any questions or concerns pertaining to this report.

Report Authorization *Kerri L. LeVanseler*
Kerri Levanseler - Director, Chemistry Laboratory

Date 26-APR-2018



General Information

Standard: USFDA CFR Title 21 Part 165.110

Date and Time Sampled: 04/04/2018 08:25 EDT | 04/11/2018 12:00 EDT

Product Description: Spring Source Water

Sample Id: **S-0001479800**
Description: Spring Source Water - 04/04/2018 08:25 EDT
Sampled Date: 04/04/2018
Received Date: 04/05/2018

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Physical Quality					
Alkalinity as CaCO3	5	ND		mg/LCaCO3	
Color	5	ND	15	Color Unit	Pass
Specific Conductance	10	25		umhos/cm	
Corrosivity	0	-4.6			
Hardness, Total	2	8		mg/LCaCO3	
Solids Total Dissolved	5	21	500	mg/L	Pass
Turbidity	0.1	ND	5	NTU	Pass
pH	0.01	6.50			
Temperature	0	21		deg. C	
Bicarbonate	5	ND		mg/L HCO3	
Odor, Threshold	1	1	3	TON	Pass
Disinfection Residuals/Disinfection By-Products					
Bromate	5	ND	10	ug/L	Pass
Monochloramine	0.05	ND		mg/L	
Dichloramine	0.05	ND		mg/L	
Nitrogen trichloride	0.05	ND		mg/L	
Chloramine, Total	0.05	ND	4	mg/L	Pass
Chlorite	10	ND	1000	ug/L	Pass
Chlorine Dioxide	0.1	ND	0.8	mg/L	Pass
Monochloroacetic Acid	2	ND		ug/L	
Monobromoacetic Acid	1	ND		ug/L	
Dichloroacetic Acid	1	ND		ug/L	
Bromochloroacetic Acid	1	ND		ug/L	
Trichloroacetic Acid	1	ND		ug/L	
Dibromoacetic Acid	1	ND		ug/L	
Total Haloacetic Acid	1	ND	60	ug/L	Pass
Chlorine, Total Residual	0.05	ND	4	mg/L	Pass
Radiologicals					
Uranium	0.001	ND	0.03	mg/L	Pass
P1 Gross Alpha	3	ND	15	pCi/L	Pass
P1 Gross Beta	4	ND	50	pCi/L	Pass
Alpha Variance +/-		2		pCi/L	
Beta Variance +/-		1		pCi/L	
Radium-226	1	ND		pCi/L	
Radium-228	1	ND		pCi/L	
Radium-226, Radium-228 Combined	1	ND	5	pCi/L	Pass
Radium 226 Variance +/-		0.2		pCi/L	
Radium 228 Variance +/-		0.2		pCi/L	
Radon	200	3000		pCi/L	
Radon Variance +/-		54		pCi/L	
Inorganic Chemicals					



Sample Id: S-0001479800

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Inorganic Chemicals					
Aluminum	0.01	0.01	0.2	mg/L	Pass
Antimony	0.0002	ND	0.006	mg/L	Pass
Arsenic	0.001	ND	0.01	mg/L	Pass
Barium	0.001	0.009	2	mg/L	Pass
Beryllium	0.0002	ND	0.004	mg/L	Pass
Bromide	10	ND		ug/L	
Cadmium	0.0002	ND	0.005	mg/L	Pass
Calcium	0.02	1.4		mg/L	
Chloride	2	ND	250	mg/L	Pass
Chromium (includes Hexavalent Chromium)	0.001	ND	0.1	mg/L	Pass
Copper	0.001	0.001	1	mg/L	Pass
Cyanide, Total	0.005	ND	0.2	mg/L	Pass
Fluoride	0.1	ND	2.4	mg/L	Pass
Iron	0.02	ND	0.3	mg/L	Pass
Lead	0.0005	ND	0.005	mg/L	Pass
Magnesium	0.02	0.99		mg/L	
Manganese	0.001	0.012	0.05	mg/L	Pass
Mercury	0.0002	ND	0.002	mg/L	Pass
Nickel	0.005	ND	0.1	mg/L	Pass
Nitrogen, Nitrate	0.01	0.04	10	mg/L N	Pass
Nitrogen, Nitrite	0.004	ND	1	mg/L N	Pass
Total Nitrate + Nitrite-Nitrogen	0.02	0.04	10	mg/L	Pass
Potassium	0.5	ND		mg/L	
Selenium	0.001	ND	0.05	mg/L	Pass
Silver	0.001	ND	0.1	mg/L	Pass
Sodium	0.2	0.6		mg/L	
Sulfate as SO4	0.5	5.5	250	mg/L	Pass
MBAS, calc. as LAS Mol.Wt. 320	0.2	ND		mg/L	
Thallium	0.0002	ND	0.002	mg/L	Pass
Phenolics	0.001	ND	0.001	mg/L	Pass
Zinc	0.01	ND	5	mg/L	Pass
Organic Chemicals					
Diquat (Ref: EPA 549.2)					
Diquat	0.4	ND	20	ug/L	Pass
Endothall (Ref: EPA 548.1) - (ug/L)					
Endothall	9	ND	100	ug/L	Pass
Glyphosate (Ref: EPA 547)					
Glyphosate	6	ND	700	ug/L	Pass
Perchlorate (Ref: EPA 314.0)					
Perchlorate	1	ND		ug/L	
2,3,7,8-TCDD (Ref: EPA 1613B)					
2,3,7,8-Tetrachlorodibenzo-p-dioxin	5	ND	30	pg/L	Pass
Carbamate Pesticides (Ref: 531.2)					
Aldicarb sulfoxide	0.5	ND		ug/L	
Aldicarb sulfone	0.5	ND		ug/L	
Oxamyl	0.5	ND	200	ug/L	Pass
Aldicarb	0.5	ND		ug/L	
Carbofuran	0.5	ND	40	ug/L	Pass
Methomyl	0.5	ND		ug/L	



Sample Id: S-0001479800

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
Carbaryl	0.5	ND		ug/L	
3-Hydroxycarbofuran	0.5	ND		ug/L	
Herbicides (Ref: EPA 515.3)					
Dalapon	1	ND	200	ug/L	Pass
Dicamba	0.1	ND		ug/L	
2,4-D	0.1	ND	70	ug/L	Pass
Pentachlorophenol	0.04	ND	1	ug/L	Pass
2,4,5-TP	0.2	ND	50	ug/L	Pass
Dinoseb	0.2	ND	7	ug/L	Pass
Picloram	0.1	ND	500	ug/L	Pass
Bentazon	0.2	ND		ug/L	
DCPA Acid Metabolites	0.2	ND		ug/L	
Semivolatile Organic Compounds (Ref: EPA 525.2)					
Hexachlorocyclopentadiene	0.1	ND	50	ug/L	Pass
EPTC	0.5	ND		ug/L	
Dimethylphthalate	2	ND		ug/L	
2,6-Dinitrotoluene	0.5	ND		ug/L	
2,4 Dinitrotoluene	0.5	ND		ug/L	
Molinate	0.1	ND		ug/L	
Diethylphthalate	2	ND		ug/L	
Propachlor	0.1	ND		ug/L	
Hexachlorobenzene	0.1	ND	1	ug/L	Pass
Simazine	0.07	ND	4	ug/L	Pass
Atrazine	0.1	ND	3	ug/L	Pass
Lindane	0.02	ND	0.2	ug/L	Pass
Terbacil	0.5	ND		ug/L	
Metribuzin	0.1	ND		ug/L	
Alachlor	0.1	ND	2	ug/L	Pass
Heptachlor	0.04	ND	0.4	ug/L	Pass
Di-n-butylphthalate	2	ND		ug/L	
Metolachlor	0.1	ND		ug/L	
Aldrin	0.1	ND		ug/L	
Heptachlor Epoxide	0.02	ND	0.2	ug/L	Pass
Butachlor	0.2	ND		ug/L	
p,p'-DDE (4,4'-DDE)	0.5	ND		ug/L	
Dieldrin	0.5	ND		ug/L	
Endrin	0.1	ND	2	ug/L	Pass
Butylbenzylphthalate	2	ND		ug/L	
bis(2-Ethylhexyl)adipate	0.6	ND	400	ug/L	Pass
Methoxychlor	0.1	ND	40	ug/L	Pass
bis(2-Ethylhexyl)phthalate (DEHP)	0.6	ND	6	ug/L	Pass
Benzo(a)Pyrene	0.02	ND	0.2	ug/L	Pass
Volatiles: EDB and DBCP (Ref: EPA 504.1)					
Ethylene Dibromide (EDB)	0.01	ND	0.05	ug/L	Pass
1,2-Dibromo-3-Chloropropane (DBCP)	0.01	ND	0.2	ug/L	Pass
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)					
Dichlorodifluoromethane	0.5	ND		ug/L	
Chloromethane	0.5	ND		ug/L	
Vinyl Chloride	0.5	ND	2	ug/L	Pass



Sample Id: S-0001479800

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
Bromomethane	0.5	ND		ug/L	
Chloroethane	0.5	ND		ug/L	
Trichlorofluoromethane	0.5	ND		ug/L	
Trichlorotrifluoroethane	0.5	ND		ug/L	
Methylene Chloride	0.5	ND	5	ug/L	Pass
1,1-Dichloroethylene	0.5	ND	7	ug/L	Pass
trans-1,2-Dichloroethylene	0.5	ND	100	ug/L	Pass
1,1-Dichloroethane	0.5	ND		ug/L	
2,2-Dichloropropane	0.5	ND		ug/L	
cis-1,2-Dichloroethylene	0.5	ND	70	ug/L	Pass
Chloroform	0.5	ND		ug/L	
Bromochloromethane	0.5	ND		ug/L	
1,1,1-Trichloroethane	0.5	ND	200	ug/L	Pass
1,1-Dichloropropene	0.5	ND		ug/L	
Carbon Tetrachloride	0.5	ND	5	ug/L	Pass
1,2-Dichloroethane	0.5	ND	5	ug/L	Pass
Trichloroethylene	0.5	ND	5	ug/L	Pass
1,2-Dichloropropane	0.5	ND	5	ug/L	Pass
Bromodichloromethane	0.5	ND		ug/L	
Dibromomethane	0.5	ND		ug/L	
cis-1,3-Dichloropropene	0.5	ND		ug/L	
trans-1,3-Dichloropropene	0.5	ND		ug/L	
1,1,2-Trichloroethane	0.5	ND	5	ug/L	Pass
1,3-Dichloropropane	0.5	ND		ug/L	
Tetrachloroethylene	0.5	ND	5	ug/L	Pass
Chlorodibromomethane	0.5	ND		ug/L	
Chlorobenzene	0.5	ND	100	ug/L	Pass
1,1,1,2-Tetrachloroethane	0.5	ND		ug/L	
Bromoform	0.5	ND		ug/L	
1,1,1,2,2-Tetrachloroethane	0.5	ND		ug/L	
1,2,3-Trichloropropane	0.5	ND		ug/L	
1,3-Dichlorobenzene	0.5	ND		ug/L	
1,4-Dichlorobenzene	0.5	ND	75	ug/L	Pass
1,2-Dichlorobenzene	0.5	ND	600	ug/L	Pass
Methyl-tert-Butyl Ether (MTBE)	0.5	ND		ug/L	
Methyl Ethyl Ketone	5	ND		ug/L	
Toluene	0.5	0.6	1000	ug/L	Pass
Ethyl Benzene	0.5	ND	700	ug/L	Pass
m+p-Xylenes	1	ND		ug/L	
o-Xylene	0.5	ND		ug/L	
Styrene	0.5	ND	100	ug/L	Pass
Isopropylbenzene (Cumene)	0.5	ND		ug/L	
n-Propylbenzene	0.5	ND		ug/L	
Bromobenzene	0.5	ND		ug/L	
2-Chlorotoluene	0.5	ND		ug/L	
4-Chlorotoluene	0.5	ND		ug/L	
1,3,5-Trimethylbenzene	0.5	ND		ug/L	
tert-Butylbenzene	0.5	ND		ug/L	
1,2,4-Trimethylbenzene	0.5	ND		ug/L	



Sample Id: **S-0001479800**

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Organic Chemicals					
sec-Butylbenzene	0.5	ND		ug/L	
p-Isopropyltoluene (Cymene)	0.5	ND		ug/L	
1,2,3-Trimethylbenzene	0.5	ND		ug/L	
n-Butylbenzene	0.5	ND		ug/L	
1,2,4-Trichlorobenzene	0.5	ND	70	ug/L	Pass
Hexachlorobutadiene	0.5	ND		ug/L	
1,2,3-Trichlorobenzene	0.5	ND		ug/L	
Naphthalene	0.5	ND		ug/L	
Benzene	0.5	ND	5	ug/L	Pass
Total Trihalomethanes	0.5	ND	80	ug/L	Pass
Total Xylenes	0.5	ND	10000	ug/L	Pass
Chlorinated Pesticides and Organohalides by EPA 508.1					
Toxaphene	0.1	ND	3	ug/L	Pass
Chlordane	0.1	ND	2	ug/L	Pass
PCB 1016	0.08	ND	0.5	ug/L	Pass
PCB 1221	0.1	ND	0.5	ug/L	Pass
PCB 1232	0.1	ND	0.5	ug/L	Pass
PCB 1242	0.1	ND	0.5	ug/L	Pass
PCB 1248	0.1	ND	0.5	ug/L	Pass
PCB 1254	0.1	ND	0.5	ug/L	Pass
PCB 1260	0.1	ND	0.5	ug/L	Pass
Endrin	0.01	ND	2	ug/L	Pass
Total PCBs	0.1	ND	0.5	ug/L	Pass

Sample Id: **S-0001480259**

Description: Spring Source Water - 04/11/2018 12:00 EDT

Sampled Date: 04/11/2018

Received Date: 04/12/2018

Testing Parameter	Reporting Limit	Result	FDA SOQ	Units	P / F
Inorganic Chemicals					
* Asbestos in Water (Ref: EPA 100.2)-Bureau Veritas					
Chrysotile Fibers	0.2	ND		MFL	
Amphibole Fibers	0.2	ND		MFL	
Single Fiber Detection Limit	0.2	ND		MFL	



<<Additional Information>>

Sample Id: S-0001479800

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Physical Quality			
Alkalinity (Ref: SM 2320-B)	10-APR-2018		
Color (Ref: SM 2120-B)	5-APR-2018	13:25	
Specific Conductance (Ref: EPA 120.1)	5-APR-2018		
Corrosivity (Ref: SM 2330-B)			
Hardness, Total (Ref: EPA 200.7)			
Solids, Total Dissolved (Ref: SM 2540-C)	5-APR-2018		
Turbidity (Ref: EPA 180.1)	5-APR-2018	13:05:00	
pH (Ref: SM4500-HB)	5-APR-2018	14:40:18	
Bicarbonate (Ref: SM 2320-B)			
Odor, Threshold Number (Ref. Standard Methods 2150 B)	05-APR-2018		
Disinfection Residuals/Disinfection By-Products			
Bromate (Ref: EPA 300.1)	10-APR-2018		
Chloramines (Ref: SM 4500-Cl-G)	5-APR-2018	12:48:00	
Chlorite (Ref: EPA 300.1)	10-APR-2018		
Chlorine Dioxide (Ref: SM 4500-ClO2-D)	5-APR-2018	12:48:00	
Haloacetic Acids (Ref: EPA 552.2)	9-APR-2018		7-APR-2018
Chlorine, Total Residual (ref. SM 4500CL-G)	5-APR-2018	12:48:00	
Radiologicals			
Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Gross Alpha and Beta Radioactivity in Drinking Water (Ref: EPA 900.0)	9-APR-2018		
Total Radium-226, Radium-228 Combined Activity (SM7500Ra-B & SM7500Ra-D)	18-APR-2018		
Radon in Water (ref: SM 7500-Rn-B)	6-APR-2018		
Inorganic Chemicals			
Aluminum (Ref: EPA 200.8)	11-APR-2018		
Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Barium in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Bromide (Ref: EPA 300.1)	10-APR-2018		
Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)	6-APR-2018		
Chloride (Ref: EPA 300.0)	5-APR-2018		
Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Copper in Drinking Water by ICPMS (Ref: EPA 200.8)			



<<Additional Information>>

Sample Id: S-0001479800

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Inorganic Chemicals			
	11-APR-2018		
Cyanide, Total (Ref: Lachat Instruments QuikChem Method 10-204-00-1-X)	12-APR-2018		
Fluoride (Ref: SM 4500-F-C)	6-APR-2018		
Iron in Drinking Water by ICPAES (Ref: EPA 200.7)	6-APR-2018		
Lead in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)	6-APR-2018		
Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Nitrogen, Nitrate (Ref: EPA 300.0)	5-APR-2018	21:12:25	
Nitrogen, Nitrite (Ref: EPA 300.0)	5-APR-2018	21:12:25	
Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)			
Potassium by ICPAES (Ref: EPA 200.7)	6-APR-2018		
Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Silver in Drinking Water by ICPMS (Ref: EPA 200.8)	12-APR-2018		
Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)	6-APR-2018		
Sulfate as SO4 (Ref: EPA 300.0)	5-APR-2018		
Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)	5-APR-2018	13:59:00	
Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
* Phenolics, Total Recoverable (Based on EPA 420.4)	11-APR-2018		
Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)	11-APR-2018		
Organic Chemicals			
Diquat (Ref: EPA 549.2)	13-APR-2018		11-APR-2018
Endothall (Ref: EPA 548.1) - (ug/L)	9-APR-2018		8-APR-2018
Glyphosate (Ref: EPA 547)	5-APR-2018		
Perchlorate (Ref: EPA 314.0)	19-APR-2018		
Test Notes			
Perchlorate analysis was performed at Eurofins Eaton Analytical: 750 Royal Oaks Drive, Suite 100 Monrovia, California 91016-3629			
EPA 331.0 was the analytical test method used to generate the Perchlorate results			
2,3,7,8-TCDD (Ref: EPA 1613B)	11-APR-2018		10-APR-2018
Carbamate Pesticides (Ref: 531.2)	24-APR-2018		
Herbicides (Ref: EPA 515.3)	19-APR-2018		19-APR-2018
Semivolatile Organic Compounds (Ref: EPA 525.2)	9-APR-2018		6-APR-2018
Volatiles: EDB and DBCP (Ref: EPA 504.1)	6-APR-2018		



<<Additional Information>>

Sample Id: S-0001479800

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Organic Chemicals			
Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)	9-APR-2018		
Chlorinated Pesticides and Organohalides by EPA 508.1	18-APR-2018		



<<Additional Information>>

Sample Id: S-0001480259

Test Parameter	Date Analyzed	Time Analyzed	Date Prepared/ Processed
Inorganic Chemicals			
# * Asbestos in Water (Ref: EPA 100.2)-Bureau Veritas	20-APR-2018	14:52	



Testing Laboratories:

Flag	Id	Address
All work performed at: (Unless otherwise specified)	NSF_AA	NSF International 789 N. Dixboro Road Ann Arbor MI 48105
#	MAXXAM	Maxxam - a Bureau Veritas Company 3380 Chastain Meadows Pkwy 300 Kennesaw, GA 30144 Arizona License #AZ0675 NY Lic. # 11645 MI Lic. # 9955

References to Testing Procedures:

NSF Reference	Parameter / Test Description
C0842	Gross Alpha and Beta Radioactivity in Drinking Water (Ref: EPA 900.0)
C0980	Total Radium-226, Radium-228 Combined Activity (SM7500Ra-B & SM7500Ra-D)
C1188	Odor, Threshold Number (Ref. Standard Methods 2150 B)
C2015	2,3,7,8-TCDD (Ref: EPA 1613B)
C2051	Radon in Water (ref: SM 7500-Rn-B)
C3012	* Asbestos in Water (Ref: EPA 100.2)-Bureau Veritas
C3013	Chloride (Ref: EPA 300.0)
C3014	Bromide (Ref: EPA 300.1)
C3015	Bromate (Ref: EPA 300.1)
C3016	Nitrogen, Nitrate (Ref: EPA 300.0)
C3017	Nitrogen, Nitrite (Ref: EPA 300.0)
C3018	Sulfate as SO4 (Ref: EPA 300.0)
C3019	Cyanide, Total (Ref: Lachat Instruments QuikChem Method 10-204-00-1-X)
C3021	* Phenolics, Total Recoverable (Based on EPA 420.4)
C3025	Chlorite (Ref: EPA 300.1)
C3033	Aluminum (Ref: EPA 200.8)
C3036	Arsenic in Drinking Water by ICPMS (Ref: EPA 200.8)
C3039	Barium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3042	Beryllium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3044	Calcium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3047	Cadmium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3053	Chromium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3059	Copper in Drinking Water by ICPMS (Ref: EPA 200.8)
C3064	Iron in Drinking Water by ICPAES (Ref: EPA 200.7)
C3072	Mercury in Drinking Water by ICPMS (Ref: EPA 200.8)
C3079	Potassium by ICPAES (Ref: EPA 200.7)
C3085	Magnesium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3086	Manganese in Drinking Water by ICPMS (Ref: EPA 200.8)
C3091	Sodium in Drinking Water by ICPAES (Ref: EPA 200.7)
C3094	Nickel in Drinking Water by ICPMS (Ref: EPA 200.8)
C3101	Lead in Drinking Water by ICPMS (Ref: EPA 200.8)
C3114	Antimony in Drinking Water by ICPMS (Ref: EPA 200.8)
C3116	Selenium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3128	Thallium in Drinking Water by ICPMS (Ref: EPA 200.8)
C3136	Zinc in Drinking Water by ICPMS (Ref: EPA 200.8)
C3144	Solids, Total Dissolved (Ref: SM 2540-C)
C3145	Turbidity (Ref: EPA 180.1)
C3155	Surfactants, Methylene Blue Active Substances (Ref: SM 5540-C)
C3157	Color (Ref: SM 2120-B)
C3158	Specific Conductance (Ref: EPA 120.1)
C3159	pH (Ref: SM4500-HB)
C3161	Hardness, Total (Ref: EPA 200.7)
C3166	Bicarbonate (Ref: SM 2320-B)



References to Testing Procedures: (Cont'd)

NSF Reference	Parameter / Test Description
C3168	Chlorine Dioxide (Ref: SM 4500-ClO2-D)
C3169	Chloramines (Ref: SM 4500-Cl-G)
C3170	Fluoride (Ref: SM 4500-F-C)
C3174	Alkalinity (Ref: SM 2320-B)
C3188	Silver in Drinking Water by ICPMS (Ref: EPA 200.8)
C3210	Corrosivity (Ref: SM 2330-B)
C3342	Total Nitrite + Nitrate-Nitrogen (Ref: EPA 300.0)
C3393	Chlorine, Total Residual (ref. SM 4500CL-G)
C4076	Carbamate Pesticides (Ref: 531.2)
C4145	Diquat (Ref: EPA 549.2)
C4154	Endothall (Ref. EPA 548.1) - (ug/L)
C4193	Glyphosate (Ref: EPA 547)
C4198	Haloacetic Acids (Ref: EPA 552.2)
C4202	Herbicides (Ref: EPA 515.3)
C4343	Semivolatile Organic Compounds (Ref: EPA 525.2)
C4411	Volatiles: EDB and DBCP (Ref: EPA 504.1)
C4496	Uranium in Drinking Water by ICPMS (Ref: EPA 200.8)
C4497	Perchlorate (Ref: EPA 314.0)
C4661	Volatiles: Regulated and Monitoring VOC's (Ref: EPA 524.2)
C4669	Chlorinated Pesticides and Organohalides by EPA 508.1

Certifications:

Arizona (# AZ0655)	California (# 03214 CA)	Connecticut (# PH-0625)
Florida (# E-87752 FL)	Hawaii	Indiana
Maryland (# 201)	Michigan (# 0048)	North Carolina (# 26701)
New Jersey (# MI770)	Nevada (# MI000302010A)	New York (# 11206)
Pennsylvania (# 68-00312)	South Carolina (# 81005)	Virginia (# 00045)
Vermont (# VT 11206)		

Test descriptions preceded by an asterisk "*" indicate that testing has been performed per NSF International requirements but is not within its scope of accreditation.

The reported result for Odor, Phenolics, Potassium, Molybdenum, Silica, Total Phosphorus, Specific Conductance, Radon, Sr-89/90 and Total Residual Chlorine cannot be used for compliance purposes within the State of Arizona.

The reported results for Asbestos, Phenolics, pH, Chlorine Dioxide, Chloramines and Total Residual Chlorine are not covered by New York State certification.

Notes:

- 1) Bottled water sold in the United States shall not contain Fluoride in excess of the levels published by the USFDA in 21 CFR Part 165.110. These levels are based on the annual average of maximum daily air temperatures at the location where the bottled water is sold at retail. Please refer to the most current edition of the regulation to determine the Fluoride maximum level that pertains to your product.
- 2) A blank on the FDA SOQ column indicates that no maximum level has been established by the FDA for that contaminant.
- 3) An ND result means that the contaminant was not detected at or above the reporting limit.

For a list of NSF International Method Detection Limits refer to http://www.nsf.org/media/enews/documents/minimum_detection_level_spreadsheet.pdf.